


Certificate of Compliance

Certificate Number **090806 - E172877**
Report Reference **E172877, August 8th, 2006**
Issue Date **2006 August 9**

Page 1 of 2



Issued to: **CARLO GAVAZZI LTD**
B42 BULEBEL INDUSTRIAL ESTATE
ZEJTUN ZTN 08 MALTA

*This is to certify that
representative samples of*

**Open Type Solid State AC Motor Controller -
RR2 series - Cat. No. RR2, followed by A or B, followed by 22, 40, 48 or 60,
followed by D, followed by 075, 150, 220, 400, 550 or 750, may be followed by
suffixes.**

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **UL 508 - Industrial Control Equipment**
CSA C22.2 No.14-05 - Industrial Control Equipment

Additional Information: **See Addendum for Electrical Ratings**

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Issued by: *Nadia Andreola*
Nadia Andreola, Engineer

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Italy, you may call +39 039 6410 101.


Reviewed by: *Matteo Redaelli*
Matteo Redaelli, Team Ldr Engineer

UL International Italia Srl

Certificate of Compliance

Certificate Number **090806 - E172877**
Report Reference **E172877, August 8th, 2006**
Issue Date **2006 August 9**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR, cUR requirements.

RATINGS:

Input -

Model	Nominal Operational Voltage	Control Voltage
RR2A22Dxxx	220 Vac, 45-65 Hz	D: 10 - 40 Vdc
RR2A40Dxxx	400 Vac, 45-65 Hz	
RR2A48Dxxx	480 Vac, 45-65 Hz	
RR2A60Dxxx	600 Vac, 45-65 Hz	

Output (FLA ratings) -

Model	HP	FLA	Model	HP	FLA
	3-phase			3-phase	
RR2x22D075	1 HP	4.2 A	RR2x22D220	3 HP	9.6 A
RR2x40D150	2 HP	4.3 A	RR2x40D400	5 HP	9.7 A
RR2x48D220	3 HP	4.8 A	RR2x48D550	7.5 HP	11.0 A
RR2x60D220	3 HP	3.9 A	RR2x60D750	10 HP	11.0 A

Output (General Purpose ratings) -

Model	General Purpose	Model	General Purpose
RR2x22D075	25A	RR2x22D220	40A
RR2x40D150		RR2x40D400	
RR2x48D220		RR2x48D550	
RR2x60D220		RR2x60D750	

Issued by: *Nadia Andreola*
Nadia Andreola, Engineer

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International Italia Srl

Reviewed by: *Matteo Redaelli*
Matteo Redaelli, Team Ldr Engineer

UL International Italia Srl